

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7165-1703:140

Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Gamewell-FCI, 12 Clintonville Road, Northford CT 06472  
Contact: Brian Carlson (781) 471-3000 FAX (781) 471-3099

**DESIGN:** Model *IdentiFlex* 610, 610VE and IF610 fire alarm control units. Power-limited, automatic, manual, coded, noncoded; local, auxiliary and remote station (Protected Premise Unit), central station, waterflow and sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and operational considerations System components:

|                         |                               |
|-------------------------|-------------------------------|
| 610, 610VE, IF610       | Control Units                 |
| 31025                   | Bus driver Module             |
| 31067                   | Processor Board               |
| 31021, 31022, 31031     | 610 Analog Addressable Module |
| LP-864                  | Line Protector                |
| 30952                   | SIM-232                       |
| 30996                   | Network Card                  |
| 31024                   | Display Card                  |
| EVX-25, -25E, -50, -50E | Audio Amplifier               |
| EVX-4Z, -2ZA            | Zone Splitter                 |
| UDACT                   | Digital Dialer                |

**RATINGS:** 120V 60Hz, 50Hz, 2A - Primary  
24V dc nominal battery voltage - Secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 8<sup>th</sup> Edition Standard.

**NOTE:** For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

**FORMERLY:** 7165-1288:154



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 15, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*

